



# Abbeville Fire Department

210 W. Vermilion St.

Phone- 337.898.4259    Abbeville La. 70510    Fax-337.898.4271

Chief Ernest Jude Mire

[firechief@cityofabbeville.net](mailto:firechief@cityofabbeville.net)

## BUILDING INSPECTIONS BY THE ABBEVILLE FIRE DEPARTMENT

- 1    Exit signs must be placed at all exits. If the business is open after 5:30 PM the exit signs must be lighted.
- 2    Fire Extinguishers are to be placed at one exit if the exits are not further than 75 feet apart. They must be 4 inches from the floor and not higher than 5 feet. A forty pound extinguisher must not be higher than 36 inches from the floor because of weight and as close to the exit as possible.
- 3    The new business form must be filled out and turned in along with a diagram or drawing of the building to the Fire Chief when he does the inspection.



# Abbeville Fire Department

210 W. Vermilion St.

Phone- 337.898.4259

Abbeville La. 70510

Fax-337.898.4271

Chief Ernest Jude Mire

[firechief@cityofabbeville.net](mailto:firechief@cityofabbeville.net)

***PLEASE PRINT***

**ADDRESS:** \_\_\_\_\_

**OWNER OF BUILDING:** \_\_\_\_\_

**OWNER OF BUILDING PHONE NUMBER:** \_\_\_\_\_

**NAME OF BUSINESS:** \_\_\_\_\_

**OWNER OF BUISINESS:** \_\_\_\_\_

**BUSINESS PHONE NUMBER:** \_\_\_\_\_

**NAME OF EMERGENCY CONTACT:** \_\_\_\_\_

**EMERGENCY CONTACT PHONE NUMBER:** \_\_\_\_\_

**\*\*\*ATTACH A DIAGRAM OF THE BUILDING FLOORPLAN OR BLUEPRINTS\*\*\***

**PLEASE BRING COMPLETED FORM AND DIAGRAM TO:**

**CITY OF ABBEVILLE**

**TAX & PERMIT OFFICE**

**101 N STATE ST**

**ABBEVILLE LA 70510**



# Abbeville Fire Department

210 W. Vermilion St.

Phone- 337.898.4259

Abbeville La. 70510

Fax-337.898.4271

Chief Ernest Jude Mire

[firechief@cityofabbeville.net](mailto:firechief@cityofabbeville.net)

## NOTIFICATION

**This is to notify the person applying for a permit to open a business in the City of Abbeville that you are to contact the Abbeville Fire Department to find out what are the requirements for life safety and fire hazard for the City of Abbeville. Please do so before you commit to anything (just because a business was operating before does not mean it meets the requirements to reopen). There is more knowledge of the codes today than was known in the past and they have to be met before occupancy will be granted.**

**If you are required to have a sprinkler system we require that you have the correct threads (3 3/32 x 8 O.D.) for our fire department.**

**The City Inspector must sign this document before occupancy will be granted. If the State Fire Marshal does the inspection we will need to see a copy of their report before we sign for occupancy.**

**Name of Business:** \_\_\_\_\_

**Building occupancy granted:** \_\_\_\_\_

**Ernest Jude Mire**

**Fire Inspector for City of Abbeville**

**Sprinkler system and  
Connection approved:** \_\_\_\_\_

**N/A**

**Ernest Jude Mire**

**Fire Inspector for City of Abbeville**