



Abbeville Fire Department

210 W. Vermilion St.

Phone- 337.898.4259 Abbeville La. 70510 Fax-337.898.4271

Chief Ernest Jude Mire

firechief@cityofabbeville.net

BUILDING INSPECTIONS BY THE ABBEVILLE FIRE DEPARTMENT

- 1 Exit signs must be placed at all exits. All exit signs must be lighted.
- 2 Fire Extinguishers are to be placed at one exit if the exits are not further than 75 feet apart. They must be 4 inches from the floor and not higher than 5 feet. A forty pound extinguisher must not be higher than 36 inches from the floor because of weight and as close to the exit as possible.
- 3 The new business form must be filled out and turned in along with a diagram or drawing of the building to the Fire Chief when he does the inspection.



Abbeville Fire Department

210 W. Vermilion St.

Phone- 337.898.4259

Abbeville La. 70510

Fax-337.898.4271

Chief Ernest Jude Mire

firechief@cityofabbeville.net

PLEASE PRINT

ADDRESS: _____

OWNER OF BUILDING: _____

OWNER OF BUILDING PHONE NUMBER: _____

NAME OF BUSINESS: _____

OWNER OF BUSINESS: _____

BUSINESS PHONE NUMBER: _____

NAME OF EMERGENCY CONTACT: _____

EMERGENCY CONTACT PHONE NUMBER: _____

*****ATTACH A DIAGRAM OF THE BUILDING FLOORPLAN OR BLUEPRINTS*****

PLEASE BRING COMPLETED FORM AND DIAGRAM TO:

CITY OF ABBEVILLE

TAX & PERMIT OFFICE

101 N STATE ST

ABBEVILLE LA 70510



Abbeville Fire Department

210 W. Vermilion St.

Phone- 337.898.4259 Abbeville La. 70510 Fax-337.898.4271

Chief Ernest Jude Mire

firechief@cityofabbeville.net

NOTIFICATION

This is to notify the person applying for a permit to open a business in the City of Abbeville that you are to contact the Abbeville Fire Department to find out what are the requirements for life safety and fire hazard for the City of Abbeville. Please do so before you commit to anything (just because a business was operating before does not mean it meets the requirements to reopen). There is more knowledge of the codes today than was known in the past and they have to be met before occupancy will be granted.

If you are required to have a sprinkler system we require that you have the correct threads (3 3/32 x 8 O.D.) for our fire department.

The City Inspector must sign this document before occupancy will be granted. If the State Fire Marshal does the inspection we will need to see a copy of their report before we sign for occupancy.

Name of Business: _____

Building occupancy granted: _____

**Ernest Jude Mire
Fire Inspector for City of Abbeville**

**Sprinkler system and
Connection approved:** _____

N/A

**Ernest Jude Mire
Fire Inspector for City of Abbeville**